

WELLS RURAL ELECTRIC COMPANY

Adopted: March 1, 1976

Reviewed: January 21, 2020

Revised: September 15, 2015

RULE NO. 17  
METER TESTS

A. Tests

1. Prior to installation

A. All single phase meters are tested by the manufacturer prior to shipment and will be deployed as received.

B. Each Three Phase meter will be tested to manufacture specifications in the deployment process.

2. Standard of Accuracy

A. The manufacturer's specifications at the time of construction for each type of meter will be used to test and determine the accuracy of each meter.

B. Whenever, on any test, a meter is found to exceed the limits defined by the manufacture specifications, it will be replaced.

3. Member/Owner

A. Member/Owner may request the company to test their meter once per year.